CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-1076:121 Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: Kidde-Fenwal, Inc., 400 Main Street, Ashland, MA 01721

Contact: Terrill Garland (508) 881-2000

DESIGN: Model DH-60, DH-60 (2W), DH-2000*, DH-2000CPDI* and DH-2000PSDI* duct smoke

> detector units. Unit consists of a plastic enclosure, optional relay and electrical components, a separately listed smoke detector, a sampling and exhaust tube. Models DH-60 and DH-60(2W) employ listee's listed Model CPD-7051D (CSFM Listing No. 7271-1076:115) or PSD-7155D (CSFM Listing No. 7272-1076:117) smoke detector. Models DH-2000CPDI and DH-2000PSDI employ listee's listed Model CPD-7052 (CSFM Listing No. 7271-1076:145) or

PSD-7152 (CSFM Listing No. 7272-1076:142) smoke detectors, respectively.

Refer to listee's data sheet for additional detailed system description and operational

considerations.

RATING: Electrical: 24 VDC, 24/120/240 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction. Suitable for use in ducts

where air velocity is between 500 and 4000 ft/min.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as duct smoke detector unit for use with separately listed electrically compatible fire

alarm control unit to shut down blowers to prevent abnormal smoke distribution. Models DH-2000, DH-2000 CPDI and DH-2000PSDI are intended for use with listed Model Fenwal Net 2000 (CSFM Listing No. 7165-1076:141) or Pegasys (CSFM Listing No. 7165-1076:146)

fire alarm control units.

*Rev. 09-06-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 12, 2002 Date Issued: Listing Expires June 30, 2003

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager